

Quality and pressure specifications - entry points

ENTRY POINTS 1) 2) 3)		Wobbe minimum	Wobbe maximum	O2 content maximum	CO2 content maximum	sulphur content in H2S max.	sum sulphur content in H2S and COS max.	mercaptan sulphur content max.	total sulphur content max.	water dewpoint	potential hydrocarbon liquid content max.	temperature entry gas minimum	temperature entry gas maximum	max. gauge pressure
		kWh/m3(n)	kWh/m3(n)	ppm	mol %	mg/m3(n)	mg/m3(n)	mg/m3(n)	mg/m3(n)	°C at 72 bar(e)	mg/m3 (n) T ≥ -3 °C at any pressure	°C	°C	bar(e)
301068	Koedijk	13.86	15.00	5	2.0	5	5	6	20	-8	5	2	40	66.2
301073	Balgzand NOGAT	13.83	15.47	5	2.5	5	5	6	20	-8	5	2	40	66.2
301084	Garijp	12.06	15.00	5	2.0	5	5	6	30	-8	5	2	40	69.0
301088	Harlingen	13.14	14.44	5	2.0	5	5	6	20	-8	5	2	40	72.0
301090	Maasvlakte	13.86	15.19	5	2.0	5	5	6	20	-8	5	2	40	79.9
301092	Middenmeer	13.83	15.00	5	1.5	5	5	6	20	-8	5	2	40	66.2
301094	Uithuizen (NGT)	13.11	15.33	5	3.0	5	5	6	20	-8	5	2	40	70.6
301108	Waalwijk	14.44	15.00	5	2.0	5	5	6	20	-8	5	2	40	66.2
300145	Oude Statenzijl (OGE)	The gas quality specifications laid down in the Energy Act apply (Energieregeling)												73.0
301118	Alkmaar UGS													66.2

1) The **gas** shall not contain other elements and impurities (such as, but not limited to, methanol, gas odorants) to the extent that the **gas** delivered cannot be transported, stored or marketed in the Netherlands without incurring additional cost for quality adjustment.

2) For the **entry points** not mentioned in this Appendix, the quality specifications of the "Energieregeling" apply unless different specifications are agreed upon in a *Grid Connection Agreement*.

3) For the **entry points** not mentioned in this Appendix, the pressure specifications are specified in a *Grid Connection Agreement*.