

Quality and pressure specifications - exit points

EXIT POINTS ^{1) 2)}		Wobbe minimum	Wobbe maximum	Calorific value minimum	Calorific value maximum	O ₂ content maximum	CO ₂ content maximum	sulphur content in H ₂ S maximum	mercaptan sulphur content maximum	total sulphur content maximum	water dewpoint	potential hydrocarbon liquid content max.	temperature exit gas minimum	temperature exit gas maximum	min. gauge pressure	max. gauge pressure
Export stations		kWh/m ³ (n)	kWh/m ³ (n)	kWh/m ³ (n)	kWh/m ³ (n)	mol %	mol %	mg/m ³ (n)	mg/m ³ (n)	mg/m ³ (n)	°C at 72 bar(e)	mg/m ³ (n) T ≥ -3 °C at any pressure	°C	°C	bar(e)	bar(e)
300131	Hilvarenbeek	The gas quality specifications laid down in the Energy Act apply (Energieregeling)													49.0	66.2
300132	Zevenaer														49.0	66.5
300133	Winterswijk														49.0	66.5
300139	Bocholtz														49.0	66.2
300140	Dinxperlo														3.0	16.0
300142	Vlieghuis														24.0	66.5
300145	Oude Statenzijl (OGE)														58.2	73.0

- 1) For the **exit points** not mentioned in this Appendix, the quality specifications of the "Regeling Gaskwaliteit" apply unless different specifications are agreed upon in a *Grid Connection Agreement*.
2) For the **exit points** not mentioned in this Appendix, the pressure specifications are specified in the *Grid Connection Agreement*.